DRC <u>SITE PLAN REVIEW AND COMMENT</u> <u>REPORT</u>

COMMENTS FROM <u>ENGINEERING</u> WILL BE AVAILABLE AT THE DRC MEETING

DRC SITE PLAN REVIEW AND COMMENT REPORT

Division: Fire **Member:** Albert Weber

828-5875

Project Name: Venetian Villa Townhomes Case #: 101-R-01

Date: 9-25-01

Comments:

1) Flow test required.

- 2) Show location of existing hydrant.
- 3) Building sprinkler system required at permit.
- 4) Show fire main, DDC and FDC on civil plans.
- 5) The stairs do not comply with NFPA 101, 18-2.2.3..2.

DRC SITE PLAN REVIEW AND COMMENT REPORT

Division: Info. Systems **Member:** Mark Pallans (GRG)

828-5790

Project Name: Venetian Villa Townhomes Case #: 101-R-01

Date: September 25, 2001

Comments:

No apparent interference will result from this plan at this time.

DRC SITE PLAN REVIEW AND COMMENT REPORT

Division: Landscape **Member:** Dave Gennaro

828-5200

Project Name: Venetian Villa Townhomes **Case #**: 101-R-01

Date: 9/25/01

Comments:

1. One of the landscape requirements for vehicular use areas is that where there is more than 2 spaces in a row that terminates in an aisle or driveway, an 8' peninsula tree island is required. There appears to be a deficiency in this regard.

- 2. Show any utilities that would affect proposed planting (such as overhead powerlines) on the Landscape Plan.
- 3. Trees require a pervious area with a minimum width of 8'. Oak trees are shown in a swale area that does not meet this minimum. Verify that other trees on the site meet pervious area requirements.
- 4. Backout parking is allowed for residential uses; however, a landscape area with a minimum width of 5' is required at the head of the parking spaces.
- 5. All Tree Preservation Ordinance requirements apply, including those regarding the guarantee for relocated trees.
- 6. Add rain sensor requirement to irrigation note.

DRC <u>SITE PLAN REVIEW AND COMMENT</u> REPORT

Division: Planning **Member:** Michael B. Ciesielski

828-5256

Applicant: Venetian Villa Townhomes, LLC **Case** #: 101-R-01

Date of September 25, 2001

meeting:

Comments:

Request: 8-unit townhouses in RC-15 zoning district.

- 1. This project must comply with ULDR Section 47-18.33, Townhouse. The dimensional requirements for RC-15 as written in ULDR Section 47-5.33 table apply unless otherwise noted in 47-18.33.
- 2. Indicate lot size for each unit, including driveways and areas held in common ownership.
- 3. Air conditioning units located in the rear of the property should be located inside the 6' high fence.
- 4. Include the dimensions of all balconies.
- 5. Show outlines of adjacent buildings on Site Plans, Landscape Plans, and Elevations. Show the relationship of the proposed to NE 26th Avenue and property lines in Elevations.
- 6. Label all easements on the architectural site plan.
- 7. Provisions satisfactory to the City Attorney, shall be made for a recordable easement over the driveway for all public utilities and for use by owners within the townhome group, as well as a recordable easement along the rear property line of the group for use by owners of the group.
- 8. Tabular information on site plan does not include parking data. Please include parking data on revised site plan.
- 9. Discuss possible side yard encroachments above 22' in height. Step-back regulations require a 1:1 (step-back for that portion of the building exceeding 22' in height). (Sec. 47-18.33.B.5.d.)

DRC <u>SITE PLAN REVIEW AND COMMENT</u> <u>REPORT</u>

- 10. A maintenance agreement is required for all townhouse developments (ULDR Section 47-18.33.B.11).
- 11. Plans must be revised to meet Sec. 47-18.33.B.9, i.e. that 75% of the fencing along the front yard of a new townhouse development abutting a public right-of-way must be of non-opaque materials such as vertical bars or picket fence.
- 12. Discuss with Engineering representative whether planters located between the garages for units # 3 and # 4 as well as units # 5 and #6 need to be relocated or eliminated (is there sufficient space for cars to either backout or turn around?)
- 13. Discuss design alternatives which would provide a minimum 3' wide sidewalk from each principal entrance to the public sidewalk as per 47-18.33.B.10.a.
- 14. Additional comments may be forthcoming at DRC meeting.
- 15. Response to these and other comments made at the DRC meeting should be provided within 90 days of this meeting or an additional DRC review may be required.

DRC <u>SITE PLAN REVIEW AND COMMENT</u> <u>REPORT</u>

Division: Police Member: Det. C.Cleary- Robitaille

Project Name: Venetian Villa Townhomes Case #: 101-R-01

Date: 9-25-01

Comments:

Owner/ Residents should be encouraged to protect their first floor windows and entranceways, particularly the French doors to the rear.

DRC <u>SITE PLAN REVIEW AND COMMENT</u> REPORT

Division: Zoning **Member:** Terry Burgess

828-5913

Project Name: Venetian Villa Townhomes **Case #**: 101-R-01

Date: 9/25/01

Comments:

- 1. Rear yard setback for townhouse developments is twenty (20) feet from the property line in accordance with section 47-18.33.B.5.c.
- 2. Dimension roofed entrances as required in section 47-18.33.B.6, a minimum of three (3) feet by five (5) feet.
- 3. Tandem parking is prohibited in accordance with section 47-20.10. A & B, remove guest parking labels from plans.
- 4. Clearly indicate five (5) foot setback dimension of mechanical equipment in along rear property line.
- 5. Dimension balconies on site plan and elevations. In accordance with section 47-19.2.B unenclosed balconies with open railings and dormers accessory to residential use are permitted to extend into the yard area a distance of three (3) feet from the face of the building, or one-third (1/3) the amount of required yard. Accessory uses which encroach into any yard area are permitted to have a total combined linear façade length not greater than twenty percent (20%) of the total linear length of the façade to which they are attached.
- 6. Provide building height from grade as defined in section 47-2.
- 7. Fences in RD-15 shall be seventy five percent (75%) non opaque materials such as vertical bars and picket fence in accordance with section 47-18.33.B.9.
- 8. Maintenance agreement and easements provisions shall be satisfactory to the City Attorney and recordable prior to C.O.
- 9. Additional comments maybe forthcoming at DRC meeting.